



Corporate Headquarters
7 Pleasant Hill Road
Cranbury, NJ 08512

Tel: 732.390.5858 • Fax: 732.390.9496
www.whitmanco.com

August 19, 2019

Thomas Bennington
DBI Construction Consultants
1261 Broadway, 9th Floor
New York, New York 10001

RE: Lead and Copper Water Testing
Former Henry Bonsall Elementary School
1575 Mt. Ephraim Avenue
Camden, New Jersey
Whitman Project #19-07-19T

Dear Mr. Bennington:

The collection of water from the water fountains and faucets located in various locations throughout the facility was completed on July 30, 2019 by Mr. David Villar and Mr. Mark Costantino of Whitman. All water samples were transported to EMSL located in Cinnaminson, New Jersey for analysis of lead and copper content in potable water.

The analysis of the 68 water samples collected from various locations in the facility were found to be below the current standards for local, state and federal regulations for lead and copper in potable water.

The laboratory analysis results, and chain of custody are provided as an attachment to this letter.

Should you have any questions or require additional information, please feel free to contact our office at 732-390-5858.

Sincerely,

Kevin T. Lovely
Senior Project Manager

KL/ks
Attachment

Creating Solutions. Exceeding Expectations.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011909349

CustomerID: WHIT53

CustomerPO:

ProjectID:

Attn: **Kevin Lovely**
Whitman Companies, Inc.
7 Pleasant Hill Rd
Cranbury, NJ 08512

Phone: (732) 390-5858
 Fax: (732) 390-9496
 Received: 07/30/19 10:30 AM

Project: Camden Prep School

Analytical Results

Client Sample Description		S1	Collected:		7/30/2019	Lab ID:		011909349-0001	
		Faculty rest room A 1st Floor							
Method	Parameter	Result	RL	Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Copper	440 D		50 µg/L	8/9/2019	VD	08/09/19 15:24	VD	
200.8	Lead	1.97		1.00 µg/L	7/31/2019	VD	07/31/19 17:51	VD	
Client Sample Description		S2	Collected:		7/30/2019	Lab ID:		011909349-0002	
		Fauculty restroom B 1st floor							
Method	Parameter	Result	RL	Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Copper	500 D		50 µg/L	7/31/2019	JD	08/01/19 14:23	JW	
200.8	Lead	1.63		1.00 µg/L	7/31/2019	JD	08/01/19 13:02	JW	
Client Sample Description		S3	Collected:		7/30/2019	Lab ID:		011909349-0003	
		Water fountain mens gym ®							
Method	Parameter	Result	RL	Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Copper	ND D		10 µg/L	8/9/2019	VD	08/09/19 15:25	VD	
200.8	Lead	ND		1.00 µg/L	7/31/2019	VD	07/31/19 17:56	VD	
Client Sample Description		S4	Collected:		7/30/2019	Lab ID:		011909349-0004	
		Water Fountain near gym (L)							
Method	Parameter	Result	RL	Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Copper	ND D		10 µg/L	8/9/2019	VD	08/09/19 15:27	VD	
200.8	Lead	ND		1.00 µg/L	7/31/2019	VD	07/31/19 17:58	VD	
Client Sample Description		S5	Collected:		7/30/2019	Lab ID:		011909349-0005	
		RM 117 faucet							
Method	Parameter	Result	RL	Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Copper	130 D		25 µg/L	8/9/2019	VD	08/09/19 15:28	VD	
200.8	Lead	ND		1.00 µg/L	7/31/2019	VD	07/31/19 18:04	VD	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011909349

CustomerID: WHIT53

CustomerPO:

ProjectID:

Attn: **Kevin Lovely**
Whitman Companies, Inc.
7 Pleasant Hill Rd
Cranbury, NJ 08512

Phone: (732) 390-5858
 Fax: (732) 390-9496
 Received: 07/30/19 10:30 AM

Project: Camden Prep School

Analytical Results

Client Sample Description S6
 Bathroom near 106
Collected: 7/30/2019 **Lab ID:** 011909349-0006

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	500 D		50 µg/L	8/9/2019 VD	08/09/19 15:30 VD
200.8	Lead	1.49		1.00 µg/L	7/31/2019 VD	07/31/19 18:06 VD

Client Sample Description S7
 Bathroom near 106
Collected: 7/30/2019 **Lab ID:** 011909349-0007

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	480 D		50 µg/L	8/9/2019 VD	08/09/19 15:31 VD
200.8	Lead	1.40		1.00 µg/L	7/31/2019 VD	07/31/19 18:07 VD

Client Sample Description S8
 Bathroom near 106
Collected: 7/30/2019 **Lab ID:** 011909349-0008

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	440 D		50 µg/L	8/9/2019 VD	08/09/19 15:33 VD
200.8	Lead	1.05		1.00 µg/L	7/31/2019 VD	07/31/19 18:09 VD

Client Sample Description S9
 Water fountain near 106
Collected: 7/30/2019 **Lab ID:** 011909349-0009

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	9.2		5.0 µg/L	8/9/2019 VD	08/09/19 15:11 VD
200.8	Lead	ND		1.00 µg/L	7/31/2019 VD	07/31/19 18:10 VD

Client Sample Description S10
 Water fountain near 106
Collected: 7/30/2019 **Lab ID:** 011909349-0010

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	9.4		5.0 µg/L	8/9/2019 VD	08/09/19 15:40 VD
200.8	Lead	ND		1.00 µg/L	7/31/2019 VD	07/31/19 18:12 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011909349

CustomerID: WHIT53

CustomerPO:

ProjectID:

Attn: **Kevin Lovely**
Whitman Companies, Inc.
7 Pleasant Hill Rd
Cranbury, NJ 08512

Phone: (732) 390-5858
 Fax: (732) 390-9496
 Received: 07/30/19 10:30 AM

Project: Camden Prep School

Analytical Results

Client Sample Description		S11 Girls bathroom near 106	Collected:		7/30/2019	Lab ID:		011909349-0011	
Method	Parameter	Result	RL	Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Copper	420 D		50 µg/L	8/9/2019	VD	08/09/19 15:37	VD	
200.8	Lead	2.28		1.00 µg/L	7/31/2019	VD	07/31/19 18:13	VD	
Client Sample Description		S12 Girls bathroom near 106	Collected:		7/30/2019	Lab ID:		011909349-0012	
Method	Parameter	Result	RL	Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Copper	370 D		50 µg/L	8/9/2019	VD	08/09/19 15:39	VD	
200.8	Lead	2.25		1.00 µg/L	7/31/2019	VD	07/31/19 18:15	VD	
Client Sample Description		S13 Large sink	Collected:		7/30/2019	Lab ID:		011909349-0013	
Method	Parameter	Result	RL	Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Copper	420 D		25 µg/L	7/31/2019	JD	08/01/19 14:54	JW	
200.8	Lead	1.24		1.00 µg/L	7/31/2019	JD	08/01/19 13:13	JW	
Client Sample Description		S14 Nurse sink	Collected:		7/30/2019	Lab ID:		011909349-0014	
Method	Parameter	Result	RL	Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Copper	900 D		50 µg/L	8/9/2019	VD	08/09/19 15:44	VD	
200.8	Lead	6.59		1.00 µg/L	7/31/2019	VD	07/31/19 18:22	VD	
Client Sample Description		S15 Nurse restroom sink	Collected:		7/30/2019	Lab ID:		011909349-0015	
Method	Parameter	Result	RL	Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Copper	750 D		50 µg/L	7/31/2019	JD	08/01/19 14:57	JW	
200.8	Lead	3.43		1.00 µg/L	7/31/2019	JD	08/01/19 13:16	JW	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011909349

CustomerID: WHIT53

CustomerPO:

ProjectID:

Attn: **Kevin Lovely**
Whitman Companies, Inc.
7 Pleasant Hill Rd
Cranbury, NJ 08512

Phone: (732) 390-5858
 Fax: (732) 390-9496
 Received: 07/30/19 10:30 AM

Project: Camden Prep School

Analytical Results

Client Sample Description		S16 Girls bathroom sink	Collected:	7/30/2019	Lab ID:	011909349-0016	
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst	
METALS							
200.8	Copper	620 D		50 µg/L	7/31/2019 JD	08/01/19 15:00	JW
200.8	Lead	4.11		1.00 µg/L	7/31/2019 JD	08/01/19 13:19	JW
Client Sample Description		S17 Girls bathroom near nurse	Collected:	7/30/2019	Lab ID:	011909349-0017	
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst	
METALS							
200.8	Copper	700 D		50 µg/L	7/31/2019 JD	08/01/19 15:02	JW
200.8	Lead	1.78		1.00 µg/L	7/31/2019 JD	08/01/19 13:58	JW
Client Sample Description		S18 Girls bathroom near nurse	Collected:	7/30/2019	Lab ID:	011909349-0018	
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst	
METALS							
200.8	Copper	630 D		50 µg/L	7/31/2019 JD	08/01/19 15:05	JW
200.8	Lead	2.85		1.00 µg/L	7/31/2019 JD	08/01/19 14:00	JW
Client Sample Description		S19 Boys bathroom by nurse	Collected:	7/30/2019	Lab ID:	011909349-0019	
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst	
METALS							
200.8	Copper	650 D		50 µg/L	8/9/2019 VD	08/09/19 15:46	VD
200.8	Lead	ND		1.00 µg/L	7/31/2019 VD	07/31/19 18:24	VD
Client Sample Description		S20 Boys bathroom by nurse	Collected:	7/30/2019	Lab ID:	011909349-0020	
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst	
METALS							
200.8	Copper	560 D		50 µg/L	8/9/2019 VD	08/09/19 15:47	VD
200.8	Lead	1.02		1.00 µg/L	7/31/2019 VD	07/31/19 18:25	VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011909349

CustomerID: WHIT53

CustomerPO:

ProjectID:

Attn: **Kevin Lovely**
Whitman Companies, Inc.
7 Pleasant Hill Rd
Cranbury, NJ 08512

Phone: (732) 390-5858
 Fax: (732) 390-9496
 Received: 07/30/19 10:30 AM

Project: **Camden Prep School****Analytical Results**

Client Sample Description S21 Boys bathroom by nurse
Collected: 7/30/2019 **Lab ID:** 011909349-0021

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	590 D		50 µg/L	8/9/2019 VD	08/09/19 15:49 VD
200.8	Lead	1.78		1.00 µg/L	7/31/2019 VD	07/31/19 18:27 VD

Client Sample Description S22
Collected: 7/30/2019 **Lab ID:** 011909349-0022

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	440 D		50 µg/L	8/9/2019 VD	08/09/19 15:50 VD
200.8	Lead	1.24		1.00 µg/L	7/31/2019 VD	07/31/19 18:28 VD

Client Sample Description S23 Girls bathroom near zoo
Collected: 7/30/2019 **Lab ID:** 011909349-0023

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	440 D		50 µg/L	8/9/2019 VD	08/09/19 15:55 VD
200.8	Lead	2.06		1.00 µg/L	7/31/2019 VD	07/31/19 18:30 VD

Client Sample Description S24 Girls bathroom near zoo
Collected: 7/30/2019 **Lab ID:** 011909349-0024

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	440 D		50 µg/L	8/9/2019 VD	08/09/19 15:57 VD
200.8	Lead	3.06		1.00 µg/L	7/31/2019 VD	07/31/19 18:31 VD

Client Sample Description S25 Girls bathroom near zoo
Collected: 7/30/2019 **Lab ID:** 011909349-0025

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper			5.0	7/31/2019 JD	
RESULTS REJECTED						
200.8	Lead	ND		1.00 µg/L	7/31/2019 JD	08/01/19 14:03 JW

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011909349

CustomerID: WHIT53

CustomerPO:

ProjectID:

Attn: **Kevin Lovely**
Whitman Companies, Inc.
7 Pleasant Hill Rd
Cranbury, NJ 08512

Phone: (732) 390-5858
 Fax: (732) 390-9496
 Received: 07/30/19 10:30 AM

Project: Camden Prep School

Analytical Results

Client Sample Description S26
Room 204
Collected: 7/30/2019
Lab ID: 011909349-0026

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	980 D		50 µg/L	8/9/2019 VD	08/09/19 15:58 VD
200.8	Lead	ND		1.00 µg/L	7/31/2019 VD	07/31/19 18:32 VD

Client Sample Description S27
Staff restroom
Collected: 7/30/2019
Lab ID: 011909349-0027

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	77		5.0 µg/L	8/9/2019 VD	08/09/19 16:00 VD
200.8	Lead	16.4		1.00 µg/L	7/31/2019 VD	07/31/19 18:34 VD

Client Sample Description S28
Water fountain (R) near 205
Collected: 7/30/2019
Lab ID: 011909349-0028

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	22 D		10 µg/L	8/9/2019 VD	08/09/19 16:13 VD
200.8	Lead	ND		1.00 µg/L	7/31/2019 VD	07/31/19 18:43 VD

Client Sample Description S29
Water fountain (L) near 205
Collected: 7/30/2019
Lab ID: 011909349-0029

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	19 D		10 µg/L	8/9/2019 VD	08/09/19 16:15 VD
200.8	Lead	ND		1.00 µg/L	7/31/2019 VD	07/31/19 18:51 VD

Client Sample Description S30
Boys bathroom near 205
Collected: 7/30/2019
Lab ID: 011909349-0030

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	480 D		50 µg/L	8/9/2019 VD	08/09/19 16:16 VD
200.8	Lead	1.35		1.00 µg/L	7/31/2019 VD	07/31/19 18:59 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011909349

CustomerID: WHIT53

CustomerPO:

ProjectID:

Attn: **Kevin Lovely**
Whitman Companies, Inc.
7 Pleasant Hill Rd
Cranbury, NJ 08512

Phone: (732) 390-5858
 Fax: (732) 390-9496
 Received: 07/30/19 10:30 AM

Project: Camden Prep School

Analytical Results

Client Sample Description S31
 Boys bathroom near 205
Collected: 7/30/2019 **Lab ID:** 011909349-0031

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	550 D		50 µg/L	8/9/2019 VD	08/09/19 16:18 VD
200.8	Lead	ND		1.00 µg/L	7/31/2019 VD	07/31/19 19:00 VD

Client Sample Description S32
 Boys bathroom near 205
Collected: 7/30/2019 **Lab ID:** 011909349-0032

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	750 D		50 µg/L	8/9/2019 VD	08/09/19 16:19 VD
200.8	Lead	ND		1.00 µg/L	7/31/2019 VD	07/31/19 19:02 VD

Client Sample Description S33
 RM 216
Collected: 7/30/2019 **Lab ID:** 011909349-0033

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	1100 D		100 µg/L	8/9/2019 VD	08/09/19 16:56 VD
200.8	Lead	1.20		1.00 µg/L	7/31/2019 VD	07/31/19 19:03 VD

Client Sample Description S34
 RM 216 (Far sink)
Collected: 7/30/2019 **Lab ID:** 011909349-0034

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	720 D		50 µg/L	8/9/2019 VD	08/09/19 16:22 VD
200.8	Lead	ND		1.00 µg/L	7/31/2019 VD	07/31/19 19:05 VD

Client Sample Description S35
 Girls bathroom near 213
Collected: 7/30/2019 **Lab ID:** 011909349-0035

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	450 D		50 µg/L	8/9/2019 VD	08/09/19 16:24 VD
200.8	Lead	1.76		1.00 µg/L	7/31/2019 VD	07/31/19 19:06 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011909349

CustomerID: WHIT53

CustomerPO:

ProjectID:

Attn: **Kevin Lovely**
Whitman Companies, Inc.
7 Pleasant Hill Rd
Cranbury, NJ 08512

Phone: (732) 390-5858
 Fax: (732) 390-9496
 Received: 07/30/19 10:30 AM

Project: Camden Prep School

Analytical Results

Client Sample Description		S36 Girls bathroom near 213	Collected:	7/30/2019	Lab ID:	011909349-0036	
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst	
METALS							
200.8	Copper	440 D		50 µg/L	8/9/2019 VD	08/09/19 16:25	VD
200.8	Lead	1.48		1.00 µg/L	7/31/2019 VD	07/31/19 19:08	VD
Client Sample Description		S37 Girls bathroom near 213	Collected:	7/30/2019	Lab ID:	011909349-0037	
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst	
METALS							
200.8	Copper	520 D		50 µg/L	8/9/2019 VD	08/09/19 16:34	VD
200.8	Lead	2.42		1.00 µg/L	7/31/2019 VD	07/31/19 19:09	VD
Client Sample Description		S38 Girls bathroom near 213	Collected:	7/30/2019	Lab ID:	011909349-0038	
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst	
METALS							
200.8	Copper	410 D		50 µg/L	8/9/2019 VD	08/09/19 16:35	VD
200.8	Lead	2.43		1.00 µg/L	7/31/2019 VD	07/31/19 19:11	VD
Client Sample Description		S39 Boys restroom near 331	Collected:	7/30/2019	Lab ID:	011909349-0039	
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst	
METALS							
200.8	Copper	940 D		50 µg/L	8/9/2019 VD	08/09/19 16:37	VD
200.8	Lead			1.00	8/9/2019 VD		VD
RESULTS REJECTED							
Client Sample Description		S40 Boys restroom near 331	Collected:	7/30/2019	Lab ID:	011909349-0040	
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst	
METALS							
200.8	Copper	450 D		50 µg/L	7/31/2019 JD	08/01/19 15:11	JW
200.8	Lead	5.09		1.00 µg/L	7/31/2019 JD	08/01/19 14:06	JW

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011909349
 CustomerID: WHIT53
 CustomerPO:
 ProjectID:

Attn: **Kevin Lovely**
Whitman Companies, Inc.
7 Pleasant Hill Rd
Cranbury, NJ 08512

Phone: (732) 390-5858
 Fax: (732) 390-9496
 Received: 07/30/19 10:30 AM

Project: **Camden Prep School**

Analytical Results

Client Sample Description		S41 Boys room near 331	Collected:	7/30/2019	Lab ID:	011909349-0041		
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS								
200.8	Copper	800 D		50 µg/L	8/9/2019	VD	08/09/19 16:38	VD
200.8	Lead	2.38		1.00 µg/L	7/31/2019	VD	07/31/19 19:21	VD
Client Sample Description		S42 Boys room near 331	Collected:	7/30/2019	Lab ID:	011909349-0042		
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS								
200.8	Copper	990 D		50 µg/L	8/9/2019	VD	08/09/19 16:40	VD
200.8	Lead	1.81		1.00 µg/L	7/31/2019	VD	07/31/19 19:22	VD
Client Sample Description		S43 Boys room near 331	Collected:	7/30/2019	Lab ID:	011909349-0043		
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS								
200.8	Copper	19		5.0 µg/L	8/9/2019	VD	08/09/19 16:06	VD
200.8	Lead	ND		1.00 µg/L	7/31/2019	VD	07/31/19 19:24	VD
Client Sample Description		S44 Water fountain near 331	Collected:	7/30/2019	Lab ID:	011909349-0044		
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS								
200.8	Copper	26		5.0 µg/L	8/9/2019	VD	08/09/19 16:27	VD
200.8	Lead	ND		1.00 µg/L	7/31/2019	VD	07/31/19 19:25	VD
Client Sample Description		S45 Girls room near 331	Collected:	7/30/2019	Lab ID:	011909349-0045		
Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS								
200.8	Copper	680 D		50 µg/L	8/9/2019	VD	08/09/19 16:41	VD
200.8	Lead	ND		1.00 µg/L	7/31/2019	VD	07/31/19 19:27	VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011909349

CustomerID: WHIT53

CustomerPO:

ProjectID:

Attn: **Kevin Lovely**
Whitman Companies, Inc.
7 Pleasant Hill Rd
Cranbury, NJ 08512

Phone: (732) 390-5858
 Fax: (732) 390-9496
 Received: 07/30/19 10:30 AM

Project: **Camden Prep School****Analytical Results**

Client Sample Description S46
 Girls room near 331
Collected: 7/30/2019 **Lab ID:** 011909349-0046

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	830 D		50 µg/L	8/9/2019 VD	08/09/19 16:43 VD
200.8	Lead	2.95		1.00 µg/L	7/31/2019 VD	07/31/19 19:28 VD

Client Sample Description S47
 Girls room near 331
Collected: 7/30/2019 **Lab ID:** 011909349-0047

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	510 D		50 µg/L	8/9/2019 VD	08/09/19 16:44 VD
200.8	Lead	2.54		1.00 µg/L	7/31/2019 VD	07/31/19 19:30 VD

Client Sample Description S48
 Girls room near 331
Collected: 7/30/2019 **Lab ID:** 011909349-0048

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	450 D		50 µg/L	8/9/2019 VD	08/09/19 16:49 VD
200.8	Lead	2.28		1.00 µg/L	7/31/2019 VD	07/31/19 19:31 VD

Client Sample Description S49
 Girls room near 300
Collected: 7/30/2019 **Lab ID:** 011909349-0049

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	350 D		50 µg/L	8/9/2019 VD	08/09/19 12:42 VD
200.8	Lead	2.22		1.00 µg/L	7/31/2019 VD	07/31/19 19:45 VD

Client Sample Description S50
 Girls room near 300
Collected: 7/30/2019 **Lab ID:** 011909349-0050

Method	Parameter	Result	RL	Units	Prep Date & Analyst	Analysis Date & Analyst
METALS						
200.8	Copper	430 D		50 µg/L	8/9/2019 VD	08/09/19 12:43 VD
200.8	Lead	2.42		1.00 µg/L	7/31/2019 VD	07/31/19 19:49 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011909349

CustomerID: WHIT53

CustomerPO:

ProjectID:

Attn: **Kevin Lovely**
Whitman Companies, Inc.
7 Pleasant Hill Rd
Cranbury, NJ 08512

Phone: (732) 390-5858
 Fax: (732) 390-9496
 Received: 07/30/19 10:30 AM

Project: Camden Prep School

Analytical Results

Client Sample Description		S51 Girls room near 300	Collected:	7/30/2019	Lab ID:	011909349-0051	
Method	Parameter	Result	RL	Units	Prep Date & Analyst		Analysis Date & Analyst
METALS							
200.8	Copper	440 D		25 µg/L	7/31/2019	JD	08/01/19 14:51 JW
200.8	Lead	1.20		1.00 µg/L	7/31/2019	JD	08/01/19 13:11 JW
Client Sample Description		S52 Girls room near 300	Collected:	7/30/2019	Lab ID:	011909349-0052	
Method	Parameter	Result	RL	Units	Prep Date & Analyst		Analysis Date & Analyst
METALS							
200.8	Copper	440 D		50 µg/L	8/9/2019	VD	08/09/19 12:45 VD
200.8	Lead	ND		1.00 µg/L	7/31/2019	VD	07/31/19 19:51 VD
Client Sample Description		S53 Bathroom by 320A	Collected:	7/30/2019	Lab ID:	011909349-0053	
Method	Parameter	Result	RL	Units	Prep Date & Analyst		Analysis Date & Analyst
METALS							
200.8	Copper	280 D		50 µg/L	8/9/2019	VD	08/09/19 12:46 VD
200.8	Lead	9.88		1.00 µg/L	7/31/2019	VD	07/31/19 19:57 VD
Client Sample Description		S59 Room 314	Collected:	7/30/2019	Lab ID:	011909349-0054	
Method	Parameter	Result	RL	Units	Prep Date & Analyst		Analysis Date & Analyst
METALS							
200.8	Copper	290 D		25 µg/L	7/31/2019	JD	08/01/19 15:14 JW
200.8	Lead	12.3		1.00 µg/L	7/31/2019	JD	08/01/19 14:09 JW
Client Sample Description		S60 Fountain near 305	Collected:	7/30/2019	Lab ID:	011909349-0055	
Method	Parameter	Result	RL	Units	Prep Date & Analyst		Analysis Date & Analyst
METALS							
200.8	Copper	45		5.0 µg/L	8/9/2019	VD	08/09/19 12:37 VD
200.8	Lead	ND		1.00 µg/L	7/31/2019	VD	07/31/19 19:58 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011909349
 CustomerID: WHIT53
 CustomerPO:
 ProjectID:

Attn: **Kevin Lovely**
Whitman Companies, Inc.
7 Pleasant Hill Rd
Cranbury, NJ 08512

Phone: (732) 390-5858
 Fax: (732) 390-9496
 Received: 07/30/19 10:30 AM

Project: Camden Prep School

Analytical Results

Client Sample Description		S61 Fountain near 305	Collected:		7/30/2019	Lab ID:		011909349-0056	
Method	Parameter	Result	RL	Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Copper	46		5.0 µg/L	8/9/2019	VD	08/09/19 12:58	VD	
200.8	Lead	ND		1.00 µg/L	7/31/2019	VD	07/31/19 19:59	VD	
Client Sample Description		S62 Boys room near 305	Collected:		7/30/2019	Lab ID:		011909349-0057	
Method	Parameter	Result	RL	Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Copper	510 D		50 µg/L	8/9/2019	VD	08/09/19 12:51	VD	
200.8	Lead	ND		1.00 µg/L	7/31/2019	VD	07/31/19 20:01	VD	
Client Sample Description		S63 Boys room near 305	Collected:		7/30/2019	Lab ID:		011909349-0058	
Method	Parameter	Result	RL	Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Copper	710 D		50 µg/L	8/9/2019	VD	08/09/19 12:52	VD	
200.8	Lead	ND		1.00 µg/L	7/31/2019	VD	07/31/19 20:02	VD	
Client Sample Description		S64 Boys room near 305	Collected:		7/30/2019	Lab ID:		011909349-0059	
Method	Parameter	Result	RL	Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Copper	700 D		50 µg/L	8/9/2019	VD	08/09/19 12:54	VD	
200.8	Lead	ND		1.00 µg/L	7/31/2019	VD	07/31/19 20:04	VD	
Client Sample Description		S65 Girls room near 313	Collected:		7/30/2019	Lab ID:		011909349-0060	
Method	Parameter	Result	RL	Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS									
200.8	Copper	500 D		50 µg/L	8/9/2019	VD	08/09/19 12:55	VD	
200.8	Lead	2.86		1.00 µg/L	7/31/2019	VD	07/31/19 20:05	VD	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011909349

CustomerID: WHIT53

CustomerPO:

ProjectID:

Attn: **Kevin Lovely**
Whitman Companies, Inc.
7 Pleasant Hill Rd
Cranbury, NJ 08512

Phone: (732) 390-5858
 Fax: (732) 390-9496
 Received: 07/30/19 10:30 AM

Project: Camden Prep School

Analytical Results

Client Sample Description S66		Collected:	7/30/2019	Lab ID:	011909349-0061
Girls room near 313					
Method	Parameter	Result	RL	Units	Prep Date & Analyst
METALS					
200.8	Copper	660 D		50 µg/L	8/9/2019 VD
200.8	Lead	1.76		1.00 µg/L	7/31/2019 VD
Client Sample Description S67		Collected:	7/30/2019	Lab ID:	011909349-0062
Girls room near 313					
Method	Parameter	Result	RL	Units	Prep Date & Analyst
METALS					
200.8	Copper	600 D		50 µg/L	8/9/2019 VD
200.8	Lead	2.66		1.00 µg/L	7/31/2019 VD
Client Sample Description S68		Collected:	7/30/2019	Lab ID:	011909349-0063
Girls room near 313					
Method	Parameter	Result	RL	Units	Prep Date & Analyst
METALS					
200.8	Copper	380 D		50 µg/L	8/9/2019 VD
200.8	Lead	6.53		1.00 µg/L	7/31/2019 VD

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution



EMSL ANALYTICAL INC.
LABORATORY PERFORMANCE

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

01909349

PHONE:
FAX:

Report To Contact Name: Kevin Lundy		Bill To Company: Whitman Co									
Company Name: Whitman		Attention To:									
Street: 7 Pleasant Hill Road		Street:									
City: Cranbury		City:									
State/Province: NJ		State/Province:									
Zip/Postal Code:		Zip/Postal Code:									
Phone: 832-390-8858		Phone:									
Fax: 832-390-8858		Fax:									
Project Name: Camden High School		Email Results To: k.lundy@whitmanco.com									
U.S. State where Samples Collected: NJ		Purchase Order:									
Number of Samples in Shipment: 68		Date of Shipment:									
Sample for Compliance? Yes <input type="checkbox"/> No <input type="checkbox"/> If yes, NPDES? <input type="checkbox"/> Other (Specify):		State Reporting Required? (Y/N)									
Samples Collected by: EMSL <input type="checkbox"/> Client <input checked="" type="checkbox"/> check one		PWS ID #: C80									
Standard Turnaround Time: <input checked="" type="checkbox"/> 2 Weeks		Samples Received Chilled? (Y/N)									
The following TATs are subject to lab approval: <input type="checkbox"/> 1 Week <input type="checkbox"/> 4 Days <input type="checkbox"/> 3 Days <input type="checkbox"/> 2 Days <input type="checkbox"/> 1 Day											
Failure to complete will hinder processing of samples		List Test(s) Needed									
Client Sample ID	Comp	Lab	Collect Date/Time	Matrix	Preservative	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	Field pH	Field pH	Field Temp. Deg C	Field Temp.	Comments
51	<input type="checkbox"/>	<input type="checkbox"/>	7/30/19	W	W	2	✓	✓			Faculty Rest Room A
52	<input type="checkbox"/>	<input type="checkbox"/>	7/30/19	W	W	2	✓	✓			Faculty Rest Room B
53	<input type="checkbox"/>	<input type="checkbox"/>	7/30/19	W	W	2	✓	✓			Water Fountain near gym (A)
54	<input type="checkbox"/>	<input type="checkbox"/>	7/30/19	W	W	2	✓	✓			Water Fountain near gym (L)
55	<input type="checkbox"/>	<input type="checkbox"/>	7/30/19	U	U	2	✓	✓			Rm 117 faucet
Released By (Signature)		Date & Time		Received By		Date & Time					
MC C80		7/30/19 11:40		Chalena WT		7/30/19 10:30					
				Barbara Lundy		7/30 10:30					
Please Indicate reporting requirements: <input checked="" type="checkbox"/> Results Only <input type="checkbox"/> Results and QC <input type="checkbox"/> Reduced Deliverables <input type="checkbox"/> Disk Deliverable <input type="checkbox"/> Other											
Instructions or Comments:											

Note: Field pH and Field Temperature are tested on the same day as the date of sample collection. (Lab) Received Temperature: °C

Page 1 of 2 pages



EMSL ANALYTICAL, INC.
LABORATORY ADDRESS HERE

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

011909349

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Client Sample ID	Failure to complete will hinder processing of samples		Matrix	Preservative	List Test(s) Needed				Field Temp			Comments
	Comp	Grab			Collect Date/Time	W=Water S=Soil A=Air SL=Sludge O= Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	Field pH	Field pH Test Time	Deg C	Field Temp Test Time	
56	<input type="checkbox"/>	<input type="checkbox"/>	2/20/17	W	2							Boiler room near 106
57	<input type="checkbox"/>	<input type="checkbox"/>										Boiler room near 106
58	<input type="checkbox"/>	<input type="checkbox"/>										Boiler room near 106
59	<input type="checkbox"/>	<input type="checkbox"/>										Water fountain near 106
510	<input type="checkbox"/>	<input type="checkbox"/>										Under Pump fair near 106
511	<input type="checkbox"/>	<input type="checkbox"/>										Girls Bathroom near 106
512	<input type="checkbox"/>	<input type="checkbox"/>										Girls Bathroom near 106
513	<input type="checkbox"/>	<input type="checkbox"/>										Girls Bathroom near 106
514	<input type="checkbox"/>	<input type="checkbox"/>										Nurse Sink
515	<input type="checkbox"/>	<input type="checkbox"/>										Nurse Bathroom Sink
516	<input type="checkbox"/>	<input type="checkbox"/>										Girls Bathroom near nurse
517	<input type="checkbox"/>	<input type="checkbox"/>										Girls Bathroom near nurse
518	<input type="checkbox"/>	<input type="checkbox"/>										Girls Bathroom near nurse
519	<input type="checkbox"/>	<input type="checkbox"/>										Boys Bathroom by nurse
520	<input type="checkbox"/>	<input type="checkbox"/>										Boys Bathroom by nurse
521	<input type="checkbox"/>	<input type="checkbox"/>										Boys Bathroom by nurse
522	<input type="checkbox"/>	<input type="checkbox"/>										

Note: Field pH and Field Temperature are tested on the same day as the date of sample collection.

(Lab) Received Temperature: _____ °C

Page 2 of 2 pages



EMSL ANALYTICAL INC.
LABORATORY PROFICIENCY TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

01909349

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Client Sample ID	Failure to complete will hinder processing of samples		Collect Date/Time	Matrix	Preservative	List Test(s) Needed				Field Test			Comments
	Comp	Grab				W=Water S=Soil A=Air SL=Sludge O=Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	Field pH	Field pH	Field Temp	Field Temp		
23 S-23	<input type="checkbox"/>	<input type="checkbox"/>	7/30/19	W	2								Girls Bathroom near 205
24 S-24	<input type="checkbox"/>	<input type="checkbox"/>											Girls Bathroom near 205
25 S-25	<input type="checkbox"/>	<input type="checkbox"/>											Girls Bathroom near 205
26 S-26	<input type="checkbox"/>	<input type="checkbox"/>											Room 204
27 S-27	<input type="checkbox"/>	<input type="checkbox"/>											Staff Restroom
28 S-28	<input type="checkbox"/>	<input type="checkbox"/>											Water Fountain (L)
29 S-29	<input type="checkbox"/>	<input type="checkbox"/>											Water Fountain (L)
30 S-30	<input type="checkbox"/>	<input type="checkbox"/>											Boys Bathroom near 205
31 S-31	<input type="checkbox"/>	<input type="checkbox"/>											Boys Bathroom near 205
32 S-32	<input type="checkbox"/>	<input type="checkbox"/>											Boys Bathroom near 205
33 S-33	<input type="checkbox"/>	<input type="checkbox"/>											Room 216 (Per. 516)
34 S-34	<input type="checkbox"/>	<input type="checkbox"/>											Girls Bathroom near 213
35 S-35	<input type="checkbox"/>	<input type="checkbox"/>											Girls Bathroom near 213
36 S-36	<input type="checkbox"/>	<input type="checkbox"/>											Girls Bathroom near 213
37 S-37	<input type="checkbox"/>	<input type="checkbox"/>											Girls Bathroom near 213
38 S-38	<input type="checkbox"/>	<input type="checkbox"/>											Girls Bathroom near 213
39 S-39	<input type="checkbox"/>	<input type="checkbox"/>											Boys Bathroom near 213

Note: Field pH and Field Temperature are tested on the same day as the date of sample collection.

(Lab) Received Temperature: _____ °C

Page 3 of 6 pages



EMSL ANALYTICAL INC.
LABORATORY PRODUCTS DIVISION

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

01909349

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Client Sample ID	Failure to complete will hinder processing of samples		Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	List Test(s) Needed				Field Test(s) Needed			Comments
	Comp	Grab				Field pH	Field pH	Field Temp	Field Temp	Field Temp			
S-40	<input type="checkbox"/>	<input type="checkbox"/>	7/30/14	W	2								Boys Room near 331
S-41	<input type="checkbox"/>	<input type="checkbox"/>											Boys Room near 331
S-42	<input type="checkbox"/>	<input type="checkbox"/>											Boys Room near 331
S-43	<input type="checkbox"/>	<input type="checkbox"/>											Waste location near 331
S-44	<input type="checkbox"/>	<input type="checkbox"/>											Waste location near 331
S-45	<input type="checkbox"/>	<input type="checkbox"/>											Boys Room near 331
S-46	<input type="checkbox"/>	<input type="checkbox"/>											Boys Room near 331
S-47	<input type="checkbox"/>	<input type="checkbox"/>											Boys Room near 331
S-48	<input type="checkbox"/>	<input type="checkbox"/>											Boys Room near 331
S-49	<input type="checkbox"/>	<input type="checkbox"/>											Boys Room near 331
S-50	<input type="checkbox"/>	<input type="checkbox"/>											Boys Room near 331
S-51	<input type="checkbox"/>	<input type="checkbox"/>											Boys Room near 331
S-52	<input type="checkbox"/>	<input type="checkbox"/>											Boys Room near 331
S-53	<input type="checkbox"/>	<input type="checkbox"/>											Boys Room near 331
S-54	<input type="checkbox"/>	<input type="checkbox"/>											Boys Room near 331
S-55	<input type="checkbox"/>	<input type="checkbox"/>											Boys Room near 331
S-61	<input type="checkbox"/>	<input type="checkbox"/>											Boys Room near 331

Note: Field pH and Field Temperature are tested on the same day as the date of sample collection.

(Lab) Received Temperature: _____ °C

Page 4 of 6 pages



EMSL ANALYTICAL, INC.
LABORATORY SERVICES DIVISION

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

011909349

PHONE:
FAX:

Report To Contact Name:				Bill To Company:						
Company Name:				Attention To:						
Street:				Street:						
City:		State/Province:		City:		State/Province:				
Phone:		Fax:		Phone:		Fax:				
Project Name:				Purchase Order:						
U.S. State where Samples Collected:				Date of Shipment:						
Sample for Compliance? Yes <input type="checkbox"/> No <input type="checkbox"/> If yes, NPDES? <input type="checkbox"/> Other (Specify):				PWS ID #:						
Samples Collected by: EMSL <input type="checkbox"/> Client <input type="checkbox"/> check one				Samples Received Chilled? (Y/N)						
Standard Turnaround Time: <input type="checkbox"/> 2 Weeks				The following TATs are subject to lab approval: <input type="checkbox"/> 1 Week <input type="checkbox"/> 4 Days <input type="checkbox"/> 3 Days <input type="checkbox"/> 2 Days <input type="checkbox"/> 1 Day						
Failure to complete will hinder processing of samples				List Test(s) Needed						
Client Sample ID	Comp	Grab	Collect Date/Time	Matrix	Preservative	Field pH	Field pH	Field Temp	Field Temp	Comments
5-62	<input type="checkbox"/>	<input type="checkbox"/>	7/30/19	W	2					Boys Room Near 305
5-63	<input type="checkbox"/>	<input type="checkbox"/>								Boys Room Near 305
5-64	<input type="checkbox"/>	<input type="checkbox"/>								Boys Room Near 305
5-65	<input type="checkbox"/>	<input type="checkbox"/>								Boys Room Near 305
5-66	<input type="checkbox"/>	<input type="checkbox"/>								Boys Room Near 305
Released By (Signature)				Received By						
Date & Time				Date & Time						
Please indicate reporting requirements: <input type="checkbox"/> Results Only <input type="checkbox"/> Results and QC <input type="checkbox"/> Reduced Deliverables <input type="checkbox"/> Disk Deliverable <input type="checkbox"/> Other										
Instructions or Comments:										

Note: Field pH and Field Temperature are tested on the same day as the date of sample collection. (Lab) Received Temperature: _____ °C

Page 5 of 6 pages

EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

Lead (Pb) Chain of Custody

EMSL Order ID (Lab Use Only):

PHONE: ()

FAX: ()

011909349

Company:		EMSL-Bill to: <input type="checkbox"/> Same <input type="checkbox"/> Different If Bill to is Different note instructions in Comments**	
Street:		<i>Third Party Billing requires written authorization from third party</i>	
City:	State/Province:	Zip/Postal Code:	Country:
Report To (Name):		Telephone #:	
Email Address:		Fax #:	Purchase Order:
Project Name/Number:		Please Provide Results: <input type="checkbox"/> Fax <input type="checkbox"/> Email	
U.S. State Samples Taken:		CT Samples: <input type="checkbox"/> Commercial/Taxable <input type="checkbox"/> Residential/Tax Exempt	
Turnaround Time (TAT) Options* - Please Check			
<input type="checkbox"/> 3 Hour	<input type="checkbox"/> 6 Hour	<input type="checkbox"/> 24 Hour	<input type="checkbox"/> 48 Hour <input type="checkbox"/> 72 Hour <input type="checkbox"/> 96 Hour <input type="checkbox"/> 1 Week <input type="checkbox"/> 2 Week
<i>*Analysis completed in accordance with EMSL's Terms and Conditions located in the Price Guide</i>			
Matrix	Method	Instrument	Reporting Limit
Chips <input type="checkbox"/> % by wt. <input type="checkbox"/> mg/cm ² <input type="checkbox"/> ppm (mg/kg)	SW846-7000B	Flame Atomic Absorption	0.01%
Air	NIOSH 7082	Flame Atomic Absorption	4 µg/filter
	NIOSH 7105	Graphite Furnace AA	0.03 µg/filter
	NIOSH 7300M/NIOSH 7303	ICP-OES	0.5 µg/filter
Wipe* <input type="checkbox"/> ASTM <input type="checkbox"/> non ASTM	SW846-7000B	Flame Atomic Absorption	10 µg/wipe
<i>*If no box checked, non-ASTM Wipe assumed</i>	SW846-6010B or C	ICP-OES	1.0 µg/wipe
TCLP	SW846-1311/7000B/SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)
	SW846-1311/SW846-6010B or C	ICP-OES	0.1 mg/L (ppm)
SPLP	SW846-1312/7000B/SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)
	SW846-1312/SW846-6010B or C	ICP-OES	0.1 mg/L (ppm)
TTLC	22 CCR App. II, 7000B/7420	Flame Atomic Absorption	40 mg/kg (ppm)
	22 CCR App. II, SW846-6010B or C	ICP-OES	2 mg/kg (ppm)
STLC	22 CCR App. II, 7000B/7420	Flame Atomic Absorption	0.4 mg/L (ppm)
	22 CCR App. II, SW846-6010B or C	ICP-OES	0.1 mg/L (ppm)
Soil	SW846-7000B	Flame Atomic Absorption	40 mg/kg (ppm)
	SW846-6010B or C	ICP-OES	2 mg/kg (ppm)
Wastewater Unpreserved <input type="checkbox"/>	SM3111B/SW846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)
Preserved with HNO ₃ pH < 2 <input type="checkbox"/>	EPA 200.9	Graphite Furnace AA	0.003 mg/L (ppm)
	EPA 200.7	ICP-OES	0.020 mg/L (ppm)
Drinking Water Unpreserved <input type="checkbox"/>	EPA 200.8	ICP-MS	0.001 mg/L (ppm)
Preserved with HNO ₃ pH < 2 <input type="checkbox"/>	EPA 200.9	Graphite Furnace AA	0.003 mg/L (ppm)
	EPA 200.5	ICP-OES	0.003 mg/L (ppm)
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter
	40 CFR Part 50	Graphite Furnace AA	3.6 µg/filter
Other:			
Name of Sampler:		Signature of Sampler:	
Sample #	Location	Volume/Area	Date/Time Sampled
567	Girls Room near 313	water / grab	7/30/19
568	Girls Room near 313	water / amb	7/30/19
Client Sample #s		Total # of Samples:	
Relinquished (Client):	Date:	Time:	
Received (Lab):	Date:	Time:	
Comments:			