

July 18, 2023

Beatriz M. Figueroa  
Regional Director of Facilities  
Uncommon Schools  
826 Broadway, 9th Floor  
New York, NY 10003

For distribution

RE: **Lead in Drinking Water Sampling**  
Camden Prep-Mt. Ephraim  
1575 Mt. Ephraim Avenue  
Camden, NJ 08103

To Whom it May Concern:

Uncommon Schools is committed to protecting student, teacher, and staff health. To protect the students and staff of the Camden Prep Copewood Middle and High School and be in compliance with the Department of Education regulations, Uncommon Schools retained Environmental Logic, LLC (EL) to test the school's drinking water for lead.

**Results of our Testing**

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, a plumbing profile for the Camden Prep Copewood Middle and High School building was prepared. Through this effort, we identified and tested all drinking water and food preparation outlets. The US Environmental Protection Agency has established a lead in drinking water action level of 15 µg/l [ppb].

On June 28, 2023, EL collected drinking water samples throughout the school.

**No lead concentrations exceeding 15 µg/l [ppb] were identified in drinking water outlets or food preparation sinks.**

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At very high levels, lead can even



cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

### How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers, and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

### Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

### For More Information

A copy of the test results is available at the Camden Prep – Mt. Ephraim Main Office for inspection by the public, including students, teachers, other school personnel, and parents. The results are also available on the Uncommon Schools website at <https://www.uncommonschools.org>. For more information about water quality at the Camden Prep Mt. Ephraim, contact Kamal Johnson, Regional Facilities Manager for Uncommon Schools at [Kamal.Johnson@uncommonschools.org](mailto:Kamal.Johnson@uncommonschools.org).

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at [www.epa.gov/lead](http://www.epa.gov/lead), call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,



Michael B. Adams  
Senior Project Manager

Enclosures: Full Analytical Data Table



Table 1

Camden Prep Copewood Middle and High School- Mt Ephraim  
 1575 Mt. Ephraim Ave  
 Camden, NJ 08103

Sample ID:	NJ Drinking Water Quality Standards	3F-WFN331-H	3F-WFN331-L	3F-WFN331-B	3F-TEACH314-S	3F-WFN305-H	3F-WFN-305-L	3F-WFN-305-B	2F-TEACH204-S	2F-WF205-H	2F-WFN205-L	2F-WFN205-B
Lab ID:	(NJAC 7:10 9/18)	70261670001	70261670002	70261670003	70261670004	70261670005	70261670006	70261670007	70261670008	70261670009	70261670010	70261670011
Date Sampled:	(µg/L)	6/28/2023	6/28/2023	6/28/2023	6/28/2023	6/28/2023	6/28/2023	6/28/2023	6/28/2023	6/28/2023	6/28/2023	6/28/2023
Analyte												
Lead	15	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0

RL - Reporting Limit  
 µg/L - Microgram Per Liter  
 <1.0 - Indicates no detection above the RL

Sample ID:	NJ Drinking Water Quality Standards	1F-COMMONS-H	1F-COMMONS-L	1F-COMMONS-B	1F-GYM-H	1F-GYM-L	1F-GYM-B	1F-SERV-RS	1F-SERV-CS	1F-SERV-LS	1F-WFN103-H	1F-WFN103-L
Lab ID:	(NJAC 7:10 9/18)	70261670012	70261670013	70261670014	70261670015	70261670016	70261670017	70261670018	70261670019	70261670020	70261670021	70261670022
Date Sampled:	(µg/L)	6/28/2023	6/28/2023	6/28/2023	6/28/2023	6/28/2023	6/28/2023	6/28/2023	6/28/2023	6/28/2023	6/28/2023	6/28/2023
Analyte												
Lead	15	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0

RL - Reporting Limit  
 µg/L - Microgram Per Liter  
 <1.0 - Indicates no detection above the RL

Sample ID:	NJ Drinking Water Quality Standards	1F-WFN103-B	1F-WFN106-H	1F-WFN106-L	1F-WFN106-B	1F-NURSE106-S	1F-NURSE111-S
Lab ID:	(NJAC 7:10 9/18)	70261670023	70261670024	70261670025	70261670026	70261670027	70261670028
Date Sampled:	(µg/L)	6/28/2023	6/28/2023	6/28/2023	6/28/2023	6/28/2023	6/28/2023
Analyte							
Lead	15	<1.0	<1.0	<1.0	<1.0	<1.0	4.2

RL - Reporting Limit  
 µg/L - Microgram Per Liter  
 <1.0 - Indicates no detection above the RL



July 06, 2023

Chris Esposito  
Environmental Logic  
11 Princess Road  
Lawrence Township, NJ 08648

RE: Project: 23-0014  
Pace Project No.: 70261670

Dear Chris Esposito:

Enclosed are the analytical results for sample(s) received by the laboratory on June 29, 2023. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Wayne Bryce  
wayne.bryce@pacelabs.com  
(631)694-3040  
Project Manager

Enclosures

cc: Quinn Ciesielski, Environmental Logic  
Nicole Maksymiw, Environmental Logic  
Paul Simms, Alpha



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## CERTIFICATIONS

Project: 23-0014

Pace Project No.: 70261670

---

### **Pace Analytical Services Long Island**

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Virginia Certification # 460302

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: 3F-WFN331-H		Lab ID: 70261670001		Collected: 06/28/23 08:20	Received: 06/29/23 09:45	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 18:14	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: 3F-WFN331-L		Lab ID: 70261670002	Collected: 06/28/23 08:21	Received: 06/29/23 09:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 18:16	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: 3F-WFN331-B		Lab ID: 70261670003	Collected: 06/28/23 08:22	Received: 06/29/23 09:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 18:20	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

<b>Sample: 3F-TEACH314-S</b>		<b>Lab ID: 70261670004</b>	Collected: 06/28/23 08:28	Received: 06/29/23 09:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 18:22	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: 3F-WFN305-H		Lab ID: 70261670005		Collected: 06/28/23 08:30	Received: 06/29/23 09:45	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 18:23	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: 3F-WFN-305-L		Lab ID: 70261670006	Collected: 06/28/23 08:31	Received: 06/29/23 09:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 18:25	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: 3F-WFN-305-B		Lab ID: 70261670007	Collected: 06/28/23 08:32	Received: 06/29/23 09:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 18:26	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: 2F-TEACH204-S</b>								
<b>Lab ID: 70261670008</b>								
Collected: 06/28/23 08:40								
Received: 06/29/23 09:45								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		07/05/23 18:31	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: 2F-WFN205-H</b>								
<b>Lab ID: 70261670009</b>								
Collected: 06/28/23 08:42								
Received: 06/29/23 09:45								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		07/05/23 18:38	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: 2F-WFN205-L		Lab ID: 70261670010	Collected: 06/28/23 08:43	Received: 06/29/23 09:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 18:43	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: 2F-WFN205-B		Lab ID: 70261670011		Collected: 06/28/23 08:44	Received: 06/29/23 09:45	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 18:44	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: IF-COMMONS-H		Lab ID: 70261670012	Collected: 06/28/23 08:52	Received: 06/29/23 09:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 18:46	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: IF-COMMONS-L		Lab ID: 70261670013	Collected: 06/28/23 08:53	Received: 06/29/23 09:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 18:47	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: IF-COMMONS-B		Lab ID: 70261670014	Collected: 06/28/23 08:54	Received: 06/29/23 09:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 18:49	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: IF-GYM-H		Lab ID: 70261670015	Collected: 06/28/23 08:58	Received: 06/29/23 09:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 18:51	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: IF-GYM-L		Lab ID: 70261670016	Collected: 06/28/23 08:59	Received: 06/29/23 09:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 18:52	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: IF-GYM-B		Lab ID: 70261670017	Collected: 06/28/23 09:00	Received: 06/29/23 09:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 18:57	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: IF-SERV-RS		Lab ID: 70261670018		Collected: 06/28/23 09:02	Received: 06/29/23 09:45	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 18:58	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: IF-SERV-CS		Lab ID: 70261670019	Collected: 06/28/23 09:03	Received: 06/29/23 09:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 19:00	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: IF-SERV-LS		Lab ID: 70261670020	Collected: 06/28/23 09:04	Received: 06/29/23 09:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 19:01	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: IF-WFN103-H		Lab ID: 70261670021	Collected: 06/28/23 09:10	Received: 06/29/23 09:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 19:03	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: IF-WFN103-L      Lab ID: 70261670022      Collected: 06/28/23 09:11      Received: 06/29/23 09:45      Matrix: Drinking Water</b>								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/05/23 19:04	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: IF-WFN103-B		Lab ID: 70261670023	Collected: 06/28/23 09:12	Received: 06/29/23 09:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 19:06	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: IF-WFN106-H		Lab ID: 70261670024	Collected: 06/28/23 09:14	Received: 06/29/23 09:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 19:07	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: IF-WFN106-L		Lab ID: 70261670025	Collected: 06/28/23 09:15	Received: 06/29/23 09:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 19:09	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: IF-WFN106-B		Lab ID: 70261670026	Collected: 06/28/23 09:16	Received: 06/29/23 09:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 19:10	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

<b>Sample: IF-NURSE106-S</b>		<b>Lab ID: 70261670027</b>		Collected: 06/28/23 09:24	Received: 06/29/23 09:45	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		07/05/23 19:15	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: 23-0014  
Pace Project No.: 70261670

Sample: IF-NURSE 111-S		Lab ID: 70261670028	Collected: 06/28/23 09:26	Received: 06/29/23 09:45	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.2</b>	ug/L	1.0	1		07/05/23 19:20	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: 23-0014  
 Pace Project No.: 70261670

QC Batch: 311244 Analysis Method: EPA 200.8  
 QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water  
 Laboratory: Pace Analytical Services - Melville  
 Associated Lab Samples: 70261670001, 70261670002, 70261670003, 70261670004, 70261670005, 70261670006, 70261670007

METHOD BLANK: 1579530 Matrix: Water  
 Associated Lab Samples: 70261670001, 70261670002, 70261670003, 70261670004, 70261670005, 70261670006, 70261670007

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	07/05/23 17:39	

LABORATORY CONTROL SAMPLE: 1579531

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.2	100	85-115	

MATRIX SPIKE SAMPLE: 1579533

Parameter	Units	70261668009 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	47.9	96	70-130	

MATRIX SPIKE SAMPLE: 1579535

Parameter	Units	70261668010 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	48.2	96	70-130	

SAMPLE DUPLICATE: 1579532

Parameter	Units	70261668009 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 1579534

Parameter	Units	70261668010 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: 23-0014
Pace Project No.: 70261670

QC Batch: 311245 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water
Laboratory: Pace Analytical Services - Melville
Associated Lab Samples: 70261670008, 70261670009, 70261670010, 70261670011, 70261670012, 70261670013, 70261670014, 70261670015, 70261670016, 70261670017, 70261670018, 70261670019, 70261670020, 70261670021, 70261670022, 70261670023, 70261670024, 70261670025, 70261670026, 70261670027

METHOD BLANK: 1579537 Matrix: Water
Associated Lab Samples: 70261670008, 70261670009, 70261670010, 70261670011, 70261670012, 70261670013, 70261670014, 70261670015, 70261670016, 70261670017, 70261670018, 70261670019, 70261670020, 70261670021, 70261670022, 70261670023, 70261670024, 70261670025, 70261670026, 70261670027

Table with 6 columns: Parameter, Units, Blank Result, Reporting Limit, Analyzed, Qualifiers. Row for Lead: ug/L, <1.0, 1.0, 07/05/23 18:28

LABORATORY CONTROL SAMPLE: 1579538
Table with 7 columns: Parameter, Units, Spike Conc., LCS Result, LCS % Rec, % Rec Limits, Qualifiers. Row for Lead: ug/L, 50, 49.2, 98, 85-115

MATRIX SPIKE SAMPLE: 1579540
Table with 8 columns: Parameter, Units, 70261670008 Result, Spike Conc., MS Result, MS % Rec, % Rec Limits, Qualifiers. Row for Lead: ug/L, <1.0, 50, 46.7, 93, 70-130

MATRIX SPIKE SAMPLE: 1579542
Table with 8 columns: Parameter, Units, 70261670009 Result, Spike Conc., MS Result, MS % Rec, % Rec Limits, Qualifiers. Row for Lead: ug/L, <1.0, 50, 46.9, 94, 70-130

SAMPLE DUPLICATE: 1579539
Table with 6 columns: Parameter, Units, 70261670008 Result, Dup Result, RPD, Qualifiers. Row for Lead: ug/L, <1.0, <1.0

SAMPLE DUPLICATE: 1579541
Table with 6 columns: Parameter, Units, 70261670009 Result, Dup Result, RPD, Qualifiers. Row for Lead: ug/L, <1.0, <1.0

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: 23-0014
Pace Project No.: 70261670

QC Batch: 311246 Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water
Laboratory: Pace Analytical Services - Melville

Associated Lab Samples: 70261670028

METHOD BLANK: 1579543 Matrix: Water
Associated Lab Samples: 70261670028

Table with 6 columns: Parameter, Units, Blank Result, Reporting Limit, Analyzed, Qualifiers. Row: Lead, ug/L, <1.0, 1.0, 07/05/23 19:17

LABORATORY CONTROL SAMPLE: 1579544

Table with 7 columns: Parameter, Units, Spike Conc., LCS Result, LCS % Rec, % Rec Limits, Qualifiers. Row: Lead, ug/L, 50, 49.5, 99, 85-115

MATRIX SPIKE SAMPLE: 1579546

Table with 8 columns: Parameter, Units, 70261670028 Result, Spike Conc., MS Result, MS % Rec, % Rec Limits, Qualifiers. Row: Lead, ug/L, 4.2, 50, 52.5, 97, 70-130

MATRIX SPIKE SAMPLE: 1579548

Table with 8 columns: Parameter, Units, 70261845001 Result, Spike Conc., MS Result, MS % Rec, % Rec Limits, Qualifiers. Row: Lead, ug/L, <1.0, 50, 49.5, 97, 70-130

SAMPLE DUPLICATE: 1579545

Table with 6 columns: Parameter, Units, 70261670028 Result, Dup Result, RPD, Qualifiers. Row: Lead, ug/L, 4.2, 4.3, 2

SAMPLE DUPLICATE: 1579547

Table with 6 columns: Parameter, Units, 70261845001 Result, Dup Result, RPD, Qualifiers. Row: Lead, ug/L, <1.0, <1.0

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



## QUALIFIERS

Project: 23-0014  
Pace Project No.: 70261670

---

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA CROSS REFERENCE TABLE**

Project: 23-0014  
 Pace Project No.: 70261670

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70261670001	3F-WFN331-H	EPA 200.8	311244		
70261670002	3F-WFN331-L	EPA 200.8	311244		
70261670003	3F-WFN331-B	EPA 200.8	311244		
70261670004	3F-TEACH314-S	EPA 200.8	311244		
70261670005	3F-WFN305-H	EPA 200.8	311244		
70261670006	3F-WFN-305-L	EPA 200.8	311244		
70261670007	3F-WFN-305-B	EPA 200.8	311244		
70261670008	2F-TEACH204-S	EPA 200.8	311245		
70261670009	2F-WFN205-H	EPA 200.8	311245		
70261670010	2F-WFN205-L	EPA 200.8	311245		
70261670011	2F-WFN205-B	EPA 200.8	311245		
70261670012	IF-COMMONS-H	EPA 200.8	311245		
70261670013	IF-COMMONS-L	EPA 200.8	311245		
70261670014	IF-COMMONS-B	EPA 200.8	311245		
70261670015	IF-GYM-H	EPA 200.8	311245		
70261670016	IF-GYM-L	EPA 200.8	311245		
70261670017	IF-GYM-B	EPA 200.8	311245		
70261670018	IF-SERV-RS	EPA 200.8	311245		
70261670019	IF-SERV-CS	EPA 200.8	311245		
70261670020	IF-SERV-LS	EPA 200.8	311245		
70261670021	IF-WFN103-H	EPA 200.8	311245		
70261670022	IF-WFN103-L	EPA 200.8	311245		
70261670023	IF-WFN103-B	EPA 200.8	311245		
70261670024	IF-WFN106-H	EPA 200.8	311245		
70261670025	IF-WFN106-L	EPA 200.8	311245		
70261670026	IF-WFN106-B	EPA 200.8	311245		
70261670027	IF-NURSE106-S	EPA 200.8	311245		
70261670028	IF-NURSE 111-S	EPA 200.8	311246		

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**NEW JERSEY CHAIN OF CUSTODY**

Westborough, MA 01581  
8 Walkup Dr.  
TEL: 508-898-9220  
FAX: 508-898-9193

Mansfield, MA 02048  
320 Forbes Blvd  
TEL: 508-822-9300  
FAX: 508-822-3288

Service Centers  
Mahwah, NJ 07430: 35 Whitney Rd, Suite 5  
Albany, NY 12205: 14 Walker Way  
Tonawanda, NY 14150: 275 Cooper Ave, Suite 105

Page 1 of 3

**WO#: 70261670**

**Project Information**

Project Name: Camden Prep - Mt. Ephraim  
Project Location: 1575 Mt. Ephraim Ave, Camden  
Project # 23-0014

**Deliverables**

NJ Full / Partial  
 EQUS (1 File)  
 EQUS (4 File)  
 Other

**Client Information**

Client: Environmental Lead  
Address: 15 Princess Rd, Suite 103  
Lawrenceville, NJ  
Phone: (908) 900-0000  
Fax:  
Email: nmaksum@envto.com

Project Manager: Chris Esposito  
ALPHA Quote #:  
Turn-Around Time

Regulatory Requirement  
 SRS Residential/Non Residential  
 SRS Impact to Groundwater  
 NJ Ground Water Quality Standards  
 NJ IGW SPLP Leachate Criteria  
 Other Drinking water

**Site Information**

Is this site impacted by Petroleum? Yes

Petroleum Product:

Standard   
Due Date:  
# of Days:

Other project specific requirements/comments:  
Samples to Paul Melville  
Please specify Metals or TAL.

For EPH, selection is REQUIRED:  
 Category 1  
 Category 2  
 1,4-Dioxane  
 8011

Sample ID	Collection		Sample Matrix	Sampler's Initials	ANALYSIS	Sample Filtration	Sample Specific Comments
	Date	Time					
3F-WFN331-H	6/28/23	8:20	DW	NM	X	Lead - drinking water	
3F-WFN331-L		8:21			X		
3F-WFN331-B		8:22			X		
3F-Teach314-S		8:28			X		
3F-WFN305-H		8:30			X		
3F-WFN305-L		8:31			X		
3F-WFN305-B		8:32			X		
2F-Teach204-S		8:40			X		
2F-WFN205-H		8:42			X		
2F-WFN205-L		8:43			X		

ALPHA Lab ID (Lab Use Only)

**Preservative Code:**

- A = None
- B = HCl
- C = HNO<sub>3</sub>
- D = H<sub>2</sub>SO<sub>4</sub>
- E = NaOH
- F = MeOH
- G = NaHSO<sub>4</sub>
- H = Na<sub>2</sub>S<sub>2</sub>O<sub>3</sub>
- K/S = Zn Ac/NaOH
- O = Other

Container Code  
Westboro: Certification No: MA935  
Mansfield: Certification No: MA015

Container Type  
Preservative

Please print clearly, legibly and completely. Samples can not be logged in and turnaround time clock will not start until any ambiguities are resolved. BY EXECUTING THIS COC, THE CLIENT HAS READ AND AGREES TO BE BOUND BY ALPHA'S TERMS & CONDITIONS. (See reverse side.)

Relinquished By:  
Paul Melville  
Date/Time: 6/28/23 11:15

Received By:  
Paul Melville  
Date/Time: 6/28/23 11:15

Westborough, MA 01581  
8 Walkup Dr.  
TEL: 508-898-9220  
FAX: 508-898-9193

Service Centers  
Mahwah, NJ 07430: 35 Whitney Rd, Suite 5  
Albany, NY 12205: 14 Walker Way  
Tonawanda, NY 14150: 275 Cooper Ave, Suite 105

Page 2 of 3

ALPHA Job #

Client Information  
Client: Same as  
Address: page 1  
Phone:  
Fax:  
Email:

Project Information  
Project Name: Camden Prep - Mt. Ephraim  
Project Location: Camden, NJ  
Project # 23-004  
(Use Project name as Project #)   
Project Manager: Chris Esposito  
ALPHA Quote #:  
Turn-Around Time

Deliverables  
 NJ Full / Reduced  
 EQUS (1 File)  EQUS (4 File)  
 Other

Billing Information  
 Same as Client Info  
PO # 21500

Site Information  
Is this site impacted by Petroleum? Yes   
Petroleum Product:

Regulatory Requirement  
 SRS Residential/Non Residential  
 SRS Impact to Groundwater  
 NJ Ground Water Quality Standards  
 NJ IGW SPLP Leachate Criteria  
 Other DW

Due Date:   
# of Days:   
Standard   
Rush (only if pre approved)

ANALYSIS  
Sample Filtration  
 Done  
 Lab to do Preservation  
 Lab to do  
(Please Specify below)  
Sample Specific Comments

These samples have been previously analyzed by Alpha   
For VOC, selection is REQUIRED:  
 Category 1  
 Category 2  
 1,4-Dioxane  
 8011

Other project specific requirements/comments:  
Samples to Paul Melville  
Please specify Metals or TAL.

Sample ID

Collection Date Time  
Date Time  
Sample Matrix  
Sampler's Initials

Sample ID	Collection Date	Collection Time	Sample Matrix	Sampler's Initials	Container Type	Date/Time
2F-WFN 205-B	6/28/23	8:44	DW	NM	P	6/28/23 1115
IF-Commons-H		8:52				
IF-Commons-L		8:53				
IF-Commons-B		8:54				
IF-Cym-H		8:58				
IF-Cym-L		8:59				
IF-Cym-B		9:00				
IF-Serv-RS		9:02				
IF-Serv-CS		9:03				
IF-Serv-L5		9:04				

Relinquished By:	Date/Time	Received By:	Date/Time
<u>Paul Melville</u>	<u>6/28/23 1115</u>	<u>Paul Melville</u>	<u>6/28/23 1115</u>
<u>Paul Melville</u>	<u>6/28/23 1634</u>	<u>Paul Melville</u>	<u>6/28/23 1634</u>
<u>Paul Melville</u>	<u>6/28/23 9:10</u>	<u>Paul Melville</u>	<u>6/28/23 9:10</u>

Westboro: Certification No: MA935  
Mansfield: Certification No: MA015

Preservative Code:  
A = None  
B = HCl  
C = HNO<sub>3</sub>  
D = H<sub>2</sub>SO<sub>4</sub>  
E = NaOH  
F = MeOH  
G = NaHSO<sub>4</sub>  
H = Na<sub>2</sub>S<sub>2</sub>O<sub>3</sub>  
K = Zn Ac/NaOH  
O = Other

Please print clearly, legibly and completely. Samples can not be logged in and turnaround time clock will not start until any ambiguities are resolved. BY EXECUTING THIS COC, THE CLIENT HAS READ AND AGREES TO BE BOUND BY ALPHA'S TERMS & CONDITIONS. (See reverse side.)





**NEW JERSEY CHAIN OF CUSTODY**

Westborough, MA 01581  
8 Walkup Dr.  
TEL: 508-898-9220  
FAX: 508-898-9193

Service Centers  
Mahwah, NJ 07430: 35 Whitney Rd, Suite 5  
Albany, NY 12205: 14 Walker Way  
Tonawanda, NY 14150: 275 Cooper Ave, Suite 105

Page 3 of 3

ALPHA Job #

**Client Information**  
Client: Same as  
Address: Same as  
Phone: page 1  
Fax:  
Email:

**Project Information**  
Project Name: Camden Prep-Mt. Ephraim  
Project Location: Camden, NJ  
Project # 23-004  
(Use Project name as Project #)  
Project Manager: Chris Esposito  
ALPHAQuote #:  
Turn-Around Time  
Standard   
Rush (only if pre approved)   
Due Date:  
# of Days:

**Billing Information**  
 Same as Client Info  
PO # 2500

**Site Information**  
Is this site impacted by Petroleum? Yes   
Petroleum Product:  
Regulatory Requirement  
 SRS Residential/Non Residential  
 SRS Impact to Groundwater  
 NJ Ground Water Quality Standards  
 NJ IGW SPLP Leachate Criteria  
 Other DW

**ANALYSIS**  
These samples have been previously analyzed by Alpha   
For VOC, selection is REQUIRED:  
 Category 1  
 Category 2  
 1,4-Dioxane  
 8011

Other project specific requirements/comments:  
Samples to Pace Melville  
Please specify Metals or TAL.

ALPHA Lab ID (Lab Use Only)	Sample ID	Collection		Sample Matrix	Sampler's Initials	Sample Filtration	Sample Specific Comments
		Date	Time				
	IF-WFN103-H	6/28/23	910	DW	NM	<input type="checkbox"/> Done <input type="checkbox"/> Lab to do Preservation <input type="checkbox"/> Lab to do	
	IF-WFN103-L		911				Lead-DW
	IF-WFN103-B		912				
	IF-WFN106-H		914				
	IF-WFN106-L		915				
	IF-WFN106-B		916				
	IF-Nurse106-S		924				
	IF-Nurse111-S		926				

**Preservative Code:**  
A = None  
B = HCl  
C = HNO<sub>3</sub>  
D = H<sub>2</sub>SO<sub>4</sub>  
E = NaOH  
F = MeOH  
G = NaHSO<sub>4</sub>  
H = Na<sub>2</sub>S<sub>2</sub>O<sub>3</sub>  
K/F = Zn Ac/NaOH  
O = Other

**Container Code:**  
P = Plastic  
A = Amber Glass  
V = Vial  
G = Glass  
B = Bacteria Cup  
C = Cube  
O = Other  
E = Encore  
D = BOD Bottle

Westboro: Certification No: MA935  
Mansfield: Certification No: MA015

Container Type: P  
Preservative: C

**Relinquished By:**  
Muel M...  
D...  
D...  
D...

**Received By:**  
D...  
D...  
D...

Date/Time: 6/28/23 1115  
6/28/23 1634  
6/29/23 9:40

Date/Time: 6/28/23 1115  
6/29/23 4:30

Please print clearly, legibly and completely. Samples can not be logged in and turnaround time clock will not start until any ambiguities are resolved. BY EXECUTING THIS COD, THE CLIENT HAS READ AND AGREES TO BE BOUND BY ALPHA'S TERMS & CONDITIONS. (See reverse side.)

No: 01-14 HC (rev. 30-Sept-2013)



**WO#: 70261670**

Client Name: Env Logic Project # \_\_\_\_\_  
 Courier:  Fed Ex  UPS  USPS  Client  Commercial  Pace  Other  
 Tracking #: \_\_\_\_\_

PM: WB Due Date: 07/14/23  
 CLIENT: ENVLOG

Custody Seal on Cooler/Box Present:  Yes  No Seals intact:  Yes  No Temperature Blank Present:  Yes  No  
 Packing Material:  Bubble Wrap  Bubble Bags  Ziploc  None  Other Type of Ice: Wet Blue None

Thermometer Used: TH158 Correction Factor: -0.3  Samples on ice, cooling process has begun  
 Cooler Temperature (°C): 1.6 Cooler Temperature Corrected (°C): 1.3 Date/Time 5035A kits placed in freezer N/A  
 Temp should be above freezing to 6.0°C

USDA Regulated Soil (  N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)?  Yes  No

Did samples originate from a foreign source including Hawaii and Puerto Rico?  Yes  No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: 6/30/23 (S)

	COMMENTS:
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	6.
Rush Turn Around Time Requested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note: if sediment is visible in the dissolved container.
Sample Labels match COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix: <u>SL</u> <u>WT</u> <u>OIL</u> <u>OTHER</u>	

Date and Initials of person checking preservation: 6/30/23 (S)

All containers needing preservation have been <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A pH paper Lot # <u>HC291595</u> All containers needing preservation are found to be in compliance with method recommendation? (HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl, NaOH>9 Sulfide, <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A NaOH>12 Cyanide) Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis	13. <input type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl Sample # Initial when completed: _____ Lot # of added preservative: _____ Date/Time preservative added: _____
Samples checked for dechlorination: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A KI starch test strips Lot # Residual chlorine strips Lot # SM 4500 CN samples checked for sul <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A Lead Acetate Strips Lot #	14. Positive for Res. Chlorine? Y N 15. Positive for Sulfide? Y N
Headspace in VOA Vials (>6mm): <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A Trip Blank Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A Trip Blank Custody Seals Present <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16. 17.

Client Notification/ Resolution: \_\_\_\_\_ Field Data Required? Y / N  
 Person Contacted: \_\_\_\_\_ Date/Time: \_\_\_\_\_  
 Comments/ Resolution: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

\* PM (Project Manager) review is documented electronically in LIMS.